

# TYPE EXAMINATION CERTIFICATE

## FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL24-400-1002-061-33 Revision no.: -

Description of the product : Fire resistant single panel swing lift landing door

Trademark : Merih

Type no. : SD-01

Name and address of the manufacturer : Merih Asansör Sanayi ve Ticaret A.Ş.  
Başkent OSB, Recep Tayyip Erdoğan Bulvarı, No:8, Malıköy,  
Temelli, Sincan, Ankara, Türkiye

Name and address of the certificate holder : Merih Asansör Sanayi ve Ticaret A.Ş.  
Başkent OSB, Recep Tayyip Erdoğan Bulvarı, No:8, Malıköy,  
Temelli, Sincan, Ankara, Türkiye

Certificate based on the following standard : EN 81-58:2022

Test laboratory : TSE Turkish Standards Institution Headship of Test and  
Calibration Center, Türkiye

Date and number of the laboratory report : 14-12-2023 / 380209

Date of type examination : 10-01-2024

Classification : The performance criteria of the EN 81-58 covered are:


	E	EI	EW
SD-01	120	-	-

Additional document with this certificate : Report belonging to the type-examination certificate  
no.: NL24-400-1002-061-33

Additional remarks : See report.

Conclusion : The lift landing door SD-01 meets the requirements of the Lifts  
Directive, Annex I section 4.2 and the EN 81-58:2022, for the  
classification indicated above

Certification decision by



P.J. Schaareman  
Product Manager C&S

Amsterdam

Date : 11-01-2024  
Valid until : 11-01-2029